


<p style="text-align: center;"><b>SOLAR COLLECTOR CERTIFICATION AND RATING</b></p> <div style="text-align: center;">  <p><b>SRCC</b> CERTIFICATION</p> </div> <p style="text-align: center;">SRCC OG-100</p>	<p style="text-align: center;"><b><u>CERTIFIED SOLAR COLLECTOR</u></b></p> <p><b>SUPPLIER:</b>    <b>Alternate Energy Technologies</b> 1057 N. Ellis Road Jacksonville, FL 32254</p> <p><b>MODEL:</b>                    Alternate Energy AE-26 <b>COLLECTOR TYPE:</b>    Glazed Flat-Plate <b>CERTIFICATION #:</b>    100-2002-001C</p>
---	--

<b>COLLECTOR THERMAL PERFORMANCE RATING</b>							
<b>Megajoules Per Panel Per Day</b>				<b>Thousands of Btu Per Panel Per Day</b>			
CATEGORY (Ti-Ta)	CLEAR DAY 23 MJ/m <sup>2</sup> ·d	MILDLY CLOUDY 17 MJ/m <sup>2</sup> ·d	CLOUDY DAY 11 MJ/m <sup>2</sup> ·d	CATEGORY (Ti-Ta)	CLEAR DAY 2000 Btu/ft <sup>2</sup> ·d	MILDLY CLOUDY 1500 Btu/ft <sup>2</sup> ·d	CLOUDY DAY 1000 Btu/ft <sup>2</sup> ·d
A (-5°C)	35	26	18	A (-9°F)	33	25	17
B (5°C)	32	23	15	B (9°F)	30	22	14
C (20°C)	27	18	10	C (36°F)	25	17	9
D (50°C)	16	8	2	D (90°F)	15	8	2
E (80°C)	6	1		E (144°F)	6	1	

A-Pool Heating (Warm Climate) B-Pool Heating (Cool Climate) C-Water Heating (Warm Climate) D-Water Heating (Cool Climate) E-Air Conditioning

Original Certification Date: November 22, 2002

**COLLECTOR SPECIFICATIONS**

<b>Gross Area:</b>	2.355 m <sup>2</sup>	25.35 ft <sup>2</sup>	<b>Net Aperture Area:</b>	2.197 m <sup>2</sup>	23.65 ft <sup>2</sup>
<b>Dry Weight:</b>	40.8 kg	90 lb	<b>Fluid Capacity:</b>	3.8 l	1.0 gal
<b>Test Pressure:</b>	1103 kPa	160 psig	<b>Max. Oper. Temp.:</b>	176.7 °C	350 °F

**COLLECTOR MATERIALS**

<b>Frame:</b>	Anodized Aluminum
<b>Cover (Outer):</b>	Low Iron Tempered Glass
<b>Cover (Inner):</b>	None
<b>Absorber Material:</b>	Tube - Copper / Plate - Copper Fin
<b>Absorber Coating:</b>	Selective Coating
<b>Insulation (Side):</b>	Polyisocyanurate
<b>Insulation (Back):</b>	Polyisocyanurate

**PRESSURE DROP**

<b>Flow</b>		<b>Δ P</b>	
ml/s	gpm	Pa	in H <sub>2</sub> O

**TECHNICAL INFORMATION**

<b>Efficiency Equation [NOTE: (P) = Ti-Ta]</b>				<b>Y Intercept</b>	<b>Slope</b>
<b>S I Units:</b>	$\eta = 0.691 - 3.3960 (P)/I - 0.0019 (P)^2/I$			0.706	-4.9099 W/m <sup>2</sup> ·°C
<b>I P Units:</b>	$\eta = 0.691 - 0.5985 (P)/I - 0.0002 (P)^2/I$			0.706	-0.865 Btu/hr·ft <sup>2</sup> ·°F
<b>Incident Angle Modifier [(S) = 1/cos θ - 1, 0° ≤ θ ≤ 60°]</b>				<b>Model Tested:</b>	AE-21
<b>K<sub>arr</sub> = 1.0</b>	-0.1939 (S)	-0.0055 (S) <sup>2</sup>		<b>Test Fluid:</b>	Water
<b>K<sub>arr</sub> = 1.0</b>	-0.20 (S)	(Linear Fit)		<b>Test Flow Rate:</b>	39 ml/s      0.62 gpm

**REMARKS:**

October, 2004

Certification must be renewed annually. For current status contact:

SOLAR RATING & CERTIFICATION CORPORATION

c/o FSEC ♦ 1679 Clearlake Road ♦ Cocoa, FL 32922 ♦ (321) 638-1537 ♦ Fax (321) 638-1010